

FORM OF QUOTATION NOTICE

Quotation Number : 2463/T1/16/KSFDC

Due date and time for receipt of
Quotations

3:30 pm on 31.07.2026

Date and time for opening of quotations

4:00 pm on 31.07.2026

Date up to which the rates are to remain
firm for acceptance

3 calendar months from the date of opening

Designation and address of officer to whom
the quotation is to be addressed

Managing Director

Kerala State Film Development Corporation Ltd

Chalachitra Kalabhavan

Vazhuthacaud, TRIVANDRUM - 14

Superscription: Quotation for ... QUOTATION No.2463/T1/16/KSFDC QUOTATIONS FOR
transformer oil filtration at Kalabhavan Theatre.....

KERALA STATE FILM DEVELOPMENT CORPORATION LTD

Oil filtering of oil cooled 160 kVA transformer

No.2463/T1/16/KSFDC

23.07.2026

Terms and conditions:

1. Sealed quotations from experienced bidders having experience in transformer oil filtering work shall be submitted in the letter head of the firm with all details.(Documentary evidence for experience shall be enclosed).
2. The contractor will have to pay security deposit of 5% of the order value without tax, within a week time of issuance of letter of intent by this office in cash or by DD payable to KSFDC Ltd. at Trivandrum.
3. The successful quotationer has to execute an agreement for oil filtration and topping up with filtered oil of Transformers with KSFDC on receipt of the work order from KSFDC before effecting the work.
4. Managing Director, KSFDC reserves' the right to reject any or all quotations without assigning any reason whatsoever.
5. The decision of KSFDC in accepting the quotation will be final.
6. Last date of receipt of quotations will be 3:30 pm on 31.07.2026. The quotations will be opened on the same day at 4pm in the presence of available quotationers.
7. Quotations shall be submitted in sealed covers super scribing "QUOTATION No.2463/T1/16/KSFDC QUOTATIONS FOR TRANSFORMER OIL FILTRATION AT KALABHAVAN THEATRE".
8. A copy of quotation notice shall be enclosed with the quote duly signed for acceptance of the terms.
9. **The quoted rate shall remain valid for three calendar months from the date of issue of work order.**
10. Quotationer may visit the site and ascertain the site condition and location of work if needed.
11. The BDV test shall only be conducted after giving sufficient time for the oil to settle down after stoppage of the filtration process. Min BDV Value after completion of filtration and cooling down of oil should be min 60KV using 2.5MM gap electrode as per IS 6792 & PPM should be less than 20.
12. Payment: payment will be made, after satisfactory completion of work and for the work executed only. Power supply will be provided by the client.

13. Tenderer should quote base price and GST separately.
14. The work should be executed in all respect as per the instructions of Engineer in-charge by arranging all required materials tools, tackles, equipments including labours, transportation etc without affecting the movie show. KSFDC will not pay anything extra on this account.
15. All safety measures should be taken by the contractor and local earthing should be provided.
16. The contractor shall be liable for making good damages/losses arising out of workmanship, breakages, pilferage etc to the KSFDC.
17. All disputes are subject to the jurisdiction of the Courts at Thiruvananthapuram.

The terms and conditions stated above are carefully read by me/us and are acceptable to me/us

Signature of the contractor with seal

Managing Director

Kerala State Film Development Corporation Ltd.

Chalachitra Kalabhavan, Vazhuthakaud,

TRIVANDRUM - 14

PRICE SCHEDULE

KERALA STATE FILM DEVELOPMENT CORPORATION LTD

Ref: No.2463/T1/16/KSFDC

Sub: **Oil filtration of 160 kVA indoor transformer at Kalabhavan Theatre**

Sl. No	Description	Unit	Qty	Rate	Amount
1	Filtration charges of insulating oil of transformer, measuring BDV of oil including labour charges & Transportation charges of filtering plant To & Fro etc (Min BDV Value after completion of filtration and cooling down of oil should be min 60KV using 2.5MM gap electrode as per IS 6792 & PPM should be less than 20.)	Litre	260		
2	Topping up with new oil for shortage of oil for transformer	Litre	20		
3	Supplying and filling new Silica Gel in existing Breather.	Kg	0.5		
Total					
Total Inc 18% GST					
(Rupees.....only)					